

I. UK DECLARATION OF CONFORMITY

| | |
|----------------------------------|-------------------------------------|
| 1. Instrument model / Instrument | 4. Object of the declaration |
| 548 | SCYLAR INT 8 (Energy calculator) |

2. Name and address of the manufacturer:

DIEHL METERING
Donaustrasse 120
90451 Nürnberg
Germany

3. This declaration of conformity is issued under the sole responsibility of the manufacturer.

5. The object of the declaration described above is in conformity with the relevant UK statutory requirements and EU requirements, insofar as they are applied:

| Statutory requirements | | Conformity assessment procedure performed by approved/notified body | | |
|------------------------|--|---|---------------------------------|-----------------|
| | | Name, No. | Conformity assessment procedure | Certificate No. |
| 2016 No. 1091 | The Electromagnetic Compatibility Regulations 2016 with Amendments | – | – | – |
| 2016 No. 1101 | The Electrical Equipment (Safety) Regulations 2016 with Amendments | – | – | – |
| 2012 No. 3032 | The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 with Amendments | – | – | – |
| 2017 No. 1206 | The Radio Equipment Regulations 2017 with Amendments | – | – | – |

6. References to the relevant designated standards or normative documents used or references to the other technical specifications in relation to which conformity is declared insofar as they are applied:

| | | |
|-----------------------------------|-------------------------|-----------------------|
| EN 1434-4:2022 | EN IEC 61326-1:2021 | EN 301 489-1 V2.2.3 |
| EN 18031-1:2024 | EN 62368-1:2014/AC:2015 | EN 301 489-3 V2.3.2 |
| EN 18031-2:2024 | EN 62479:2010 | EN 301 489-52 V1.3.1 |
| EN 61000-6-3:2007/A1:2011/AC:2012 | EN 300 220-1 V3.1.1 | EN 301 908-1 V15.2.1 |
| EN IEC 61000-6-3:2021 | EN 300 220-2 V3.1.1 | EN 301 908-13 V13.2.1 |
| EN 61326-1:2013 | EN 300 330 V2.1.1 | EN IEC 63000:2018 |

II. STATEMENT OF COMPLIANCE IN ACCORDANCE WITH THE PRODUCT SECURITY AND TELECOMMUNICATIONS INFRASTRUCTURE ACT 2022 AND THE PRODUCT SECURITY AND TELECOMMUNICATIONS INFRASTRUCTURE (SECURITY REQUIREMENTS FOR RELEVANT CONNECTABLE PRODUCTS) REGULATIONS 2023 ("PSTI REGS")

- The product described above complies with the relevant security requirements specified in Schedule 1 of the PSTI Regs.
- Factory default state: not applicable.
- Defined support period for the product current from the date of supply of the product: please see product warranty information. The firmware of the product cannot be altered. The software in the product is not able to be updated or supported via over-the-air updates.
Please note that defined support period stated herein, is only applicable to products sold in the UK.
- Contact point for the reporting of any security issues with the product described above:
please contact us at: metering-uk-sales@diehl.com

Nürnberg, 2025-09-22

Dr. Christof Bosbach
President of the Division Board
Diehl Metering

Reiner Edel
Member of the Division Board
Finance & Administration